




Renseignement technique AEA I n° 26533

Groupe 122	Plaques et nattes d'isolation thermique	
Requérant	Sager AG Dornhügelstrasse 10 5724 Dürrenäsch Schweiz	
Fabricant	Sager AG 5724 Dürrenäsch Schweiz	
Produit	SAGLAN SBR / SBR SPARREN / SI30 / SI30 GEKREPPT	
Description	Plaque en laine de verre avec/sans revêtement, PSmax=80kg/m3	
Utilisation	RF1	
Documentation	MPA, Stuttgart: Klassifizierungsbericht '902 7272 015-82' (02.06.2015), Bescheinigung der Leistungsbeständigkeit '0672-CPR-0317 ' (28.03.2014); -: LE 'sa-0003-sbrplus-rk-a1-150630' (30.06.2015), LE 'sa-0003-si30-rk-a1-150630' (30.06.2015), LE 'sa-0003-si30k-rk-a1-150630' (30.06.2015)	
Conditions d'essai	EN ISO 1182, EN ISO 1716, EN 13823	
Appréciation	Classification:	A1
Durée de validité	31.12.2021	
Date d'édition	10.02.2016	Organisme de reconnaissance des autorités cantonales de protection incendie
Remplace l'attestation du	-	


Michael Binz


Gérald Rappo

